

SECTION 6 AGGREGATE SUBBASE

6.01 DESCRIPTION

Aggregate subbase shall conform to Section 25 of the State Standard Specifications and shall be Class 2 ASB. Thickness shown on the plans shall be the minimum section allowed.

7.02 MEASUREMENT AND PAYMENT

Aggregate Subbase shall be measured by the cubic yard as calculated on the basis of the dimensions shown on the plans adjusted by the amount of any change ordered by the City Engineer. No allowance will be made for aggregate base placed outside said dimensions unless otherwise ordered by the City Engineer.

Payment will be paid for at the contract price per cubic yard. Payment shall include full compensation for furnishing of all labor, materials, tools, equipment, and incidentals, and for doing all the work involved in constructing aggregate subbase, complete in place, as shown on the plans, and as specified in these specifications, and as directed by the City Engineer.